



BRUHAT BENGALURU MAHANAGARA PALIKE

Medical Officer of Health, Byatarayanapura, Yelahanka Zone, Bangalore-92

NO: BBMP/YZ/MOH(BTP)/PR/40/23-24

Date:26.06.2023

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certifies that an inspection team headed by Senior Health Inspector Ward No.05-BBMP inspected the “WISDOM MONTFORT INTERNATIONAL SCHOOL”, Agrahara Layout Road, Thirumenahalli, Yelahanka, Bangalore-560064 on 26.06.2023 and found that “WISDOM MONTFORT INTERNATIONAL SCHOOL” has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the State Government.

The above is valid for a period of - 1 year


Medical Officer of Health,
Byatarayanapura Division
Yelahanka Zone
BBMP, Bangalore-92
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಬೆಂಗಳೂರು

To,

The Principal
Wisdom Montfort International School
Agrahara Layout Road,
Thirumenahalli, Yelahanka,
Bangalore-560064



SLN TESTING LABORATORY

Recognized by MOEF & CC , ISO 9001:2015 , ISO14001:2015 ,

ISO 45001:2018 & GLP Certified Laboratory

#23, JDN Layout, 10th Cross , Raghavendra Industrial Area , Thigalarapalya Main Road,
Peenya 2nd Stage , Bengaluru - 560058, Karnataka.

Mob : 9538888098 , 9538888097, E - mail: info@slnlabs.com , Web : www.slnlabs.com



TEST REPORT

Page No. 1 of 1

Report No : SLNTL23001000524	Report Date : 18/10/2023
Issued To: M/s. Wisdom montfort international school Agrahara Badavane, Thirumenahalli, Yelahanka, Bengaluru, Karnataka 560064	Customer Reference : Verbal
	Date of Receipt : 13/10/2023
	Date of test start : 13/10/2023
	Date of Completion of test : 18/10/2023
Sample Received By: Customer	Sample Particulars : RO Water

Parameters	Results	Maximum Acceptable Limits (in mg/L)	Maximum Permissible Limits (in mg/L)	Test Method
		(As per IS 10500:2012)		
Colour, Hazen Units	<5	5	15	IS:3025/Part-4
Odour	Agreeable	Agreeable	Agreeable	IS:3025/Part-5
Turbidity, NTU	<1.0	1	5	IS:3025/Part-10
pH Value	7.45	6.5 – 8.5	No Relaxation	IS:3025/Part-11
Total Hardness as CaCO ₃ , mg/L	32.0	200	600	IS:3025/Part-21
Calcium as Ca, mg/L	8.1	75	200	IS:3025/Part-40
Magnesium as Mg, mg/L	2.9	30	100	IS:3025/Part-46
Chloride as Cl, mg/L	10.0	250	1000	IS:3025/Part-32
Total Dissolved Solids, mg/L	103.0	500	2000	IS:3025/Part-16
Sulphate as SO ₄ , mg/L	1.0	200	400	IS:3025/Part-24
Nitrate as NO ₃ , mg/L	<0.5	45	No Relaxation	IS:3025/Part-34
Fluoride as F, mg/L	<0.1	1.0	1.5	IS:3025/Part-60
Iron as Fe, mg/L	<0.1	0.3	No Relaxation	IS:3025/Part-53
Chromium as Cr ⁶⁺ , mg/L	<0.05	0.05	No Relaxation	IS:3025/Part-52
Zinc as Zn, mg/L	<0.5	5	15	IS:3025/Part-49
Copper as Cu, mg/L	<0.05	0.05	1.5	IS:3025/Part-42
Manganese as Mn, mg/L	<0.1	0.1	0.3	IS:3025/Part-59
Aluminium as Al, mg/L	<0.03	0.03	0.2	IS:3025/Part-55
Boron as B, mg/L	<0.1	0.5	1	IS:3025/Part-57
Total Alkalinity as CaCO ₃ , mg/L	24.0	200	600	IS:3025/Part-23
Total Coli form, MPN/100ml	Not Detected	Not Detectable		IS 1622-1981
E. Coli, MPN/100ml	Not Detected	Not Detectable		IS 1622-1981

Remarks: The given water sample meets to maximum acceptable limits as per **IS 10500:2012** for above physical, chemical and microbiological testing. The water is potable.

*****End of the Report*****



Authorised Signatory

Note : 1. The results listed pertain only to the tested samples and applicable parameters.

2. Samples will be destroyed after 15 days from the date of issue of test certificates unless & otherwise specified and all perishable samples will be destroyed immediately after tests conducted.

3. This report is not be reproduced either wholly or in part and can not be used as evidence in the court of law and should not be used in any advertising media without prior written permission.

4. Sampling not done by us, unless specified.



Acc no:-NB1112041N
www.jas.anz.org/register

PR/Water Test Report/012/23-24



PR INDUSTRIAL SUPPLIES

ISO 9001:2008

www.prindustries.org

09/10/2023

Mr. Wisdom Montfort International School,
Hegde Nagar,
Bangalore.

RAW WATER TEST REPORT

SI No.	CHARACTERISTICS	RAW WATER	PERMISSABLE LIMIT
1.	Total Dissolved Solids (TDS)	± 355 ppm	± 50 ppm
2.	Total Hardness	± 200 ppm	± 20 ppm
3.	P _H Value	7.0	7
4.	Turbidity (suspended impurities)	Traces found	Should be Neutralized
5.	Calcium and sodium salts	Traces found	Should be Neutralized
6.	Phosphates and Nitrates	Traces found	Should be Neutralized

www.prindustries.org

For PR INDUSTRIAL SUPPLIES


M.K Krishna Raj
☎ 9886394734
✉ prindusdtrial@gmail.com
🌐 www.prindustries.org



"Customer Satisfaction is the pulse of our organization"

Consultants & Solution Providers for:

Water Softener Commercial RO Plants Water Treatment Plants Sewage Treatment Plants

37/38, Papamma Layout, Ramamurthy nagar, Bangalore- 560 016.

Ph. 09886394734 / 09739391571 email: prindusdtrial@gmail.com / admin@prindustries.org

Branches: **CHENNAI HYDERABAD COCHIN**